
Readme / Installationsanleitung für Hotfix 1 für DIGSI 4.71+SP1

Neuerungen und Änderungen

Folgendes Fehlerbild wird mit diesem Hotfix behoben:

Fehler 27061 – Anwenderdefinierter Messwert kann nur in Primär-Messwertfenster rangiert werden
Dieser Fehler tritt nur bei Geräten mit IEC61850-Protokoll auf.

Systemvoraussetzungen

Siehe DIGSI V4.71.

Hinweise zur Benutzung / Einschränkungen

Für die Installation des Hotfix muss DIGSI 4.71 mit SP1 auf Ihrem PC installiert sein.

Kompatibilität

Hotfix 1 für DIGSI 4.71+SP1 darf nur mit DIGSI 4.71 eingesetzt werden.

Lieferumfang / Installation

Datei mit der Bezeichnung DINTZUG.DLL.

1. Stellen Sie sicher, dass DIGSI 4.71 und das Service Pack 1 auf dem PC installiert sind.
2. Bitte schließen Sie DIGSI 4.71 bevor Sie das Hotfix 1 für DIGSI 4.71+SP1 installieren.
3. Kopieren Sie die Datei DINTZUG.DLL in Abhängigkeit Ihrer DIGSI-Installation in das Verzeichnis, in dem Sie die Datei „DIGSI4.EXE“ finden. Üblicherweise ist dies das Verzeichnis: C:\Siemens\Digsi4\
4. Bestätigen Sie die Frage, ob Sie die bestehende Datei überschreiben wollen, mit "Ja".

Hinweise zur Installation

So erkennen Sie, dass das Hotfix 1 für DIGSI 4.71+SP1 installiert ist: Im "Eigenschaften"-Dialog der Datei DINTZUG.DLL (im MS Windows-Explorer) auf der Karte "Version" ist die Produktversion "04.71.27" eingetragen.

Deinstallation

Es ist weder möglich noch nötig, das Hotfix zu deinstallieren.

Hotline-Kontakt

Um Unterstützung bei der Installation und Benutzung dieses Hotfixes zu bekommen, wenden Sie sich bitte an unsere Hotline.

Hotfix 1 für DIGSI 4.71+SP1
Readme

Fon: +49 - 180 - 524 7000

Fax: +49 - 180 - 524 2471

eMail: ptd.support@siemens.com

Readme / Installation Instructions for Hotfix 1 for DIGSI 4.71+SP1

New Features and Modifications

With this Hotfix the following error is corrected:

Error 27061 – User-defined measured value can only be allocated to primary measured value window

This error occurs only with devices with IEC61850 protocol.

System Requirements

See DIGSI V4.71.

Comments to usage / restrictions

DIGSI 4.71 with SP1 must be installed on your PC.

Compatibility

Hotfix 1 for DIGSI 4.71+SP1 can only be used to update DIGSI 4.71.

Contents of the Consignment / Installation

File with the name DINTZUG.DLL.

1. Make sure, that DIGSI 4.71 and Service Pack 1 are installed on your PC.
2. Please close DIGSI 4.71 before you install the Hotfix 1 for DIGSI 4.71+SP1.
3. Copy the file "DINTZUG.DLL" into the folder, which contains the file "DIGSI4.EXE". This is depending on your DIGSI installation. The usual installation path is: C:\Siemens\Digsi4\
4. Confirm the question whether to overwrite the existing file with "Yes".

Remarks to Installation

How to recognize that Hotfix 1 for DIGSI 4.71+SP1 has been installed:

In the "Properties" dialog of the file "DINTZUG.DLL" (MS Windows-Explorer) under the "Version" card, you can identify the file as product version "04.71.27".

De-Installation

It is neither possible nor necessary to uninstall the hotfix.

Hotline

To get help with installation and usage of this hotfix, please ask our hotline.

Phone: +49 - 180 - 524 7000

Hotfix 1 für DIGSI 4.71+SP1
Readme

Fax: +49 - 180 - 524 2471

eMail: ptd.support@siemens.com