

---

## Readme/Installationsanleitung für DIGSI V4.84 Hotfix 1

### Neuerungen und Änderungen

Folgende Fehler werden mit dem DIGSI V4.84 Hotfix 1 behoben:

#### **IEC 61850 Station kann nicht aktualisiert werden**

Die Probleme beim Aktualisieren in deutscher Sprache sind behoben.

### Systemvoraussetzungen

Siehe DIGSI V4.84.

### Hinweise zur Benutzung/Einschränkungen

DIGSI V4.84 muss auf Ihrem PC installiert sein.

### Kompatibilität

DIGSI V4.84 Hotfix 1 darf nur mit DIGSI V4.84 eingesetzt werden.

### Lieferumfang

Das DIGSI V4.84 Hotfix 1 beinhaltet folgende Dateien/Ordner:

- lec2Map.dll
- GNL\_DIGSI-V4.84\_HF1\_Readme.pdf

### Installation

1. Stellen Sie sicher, dass DIGSI V4.84 auf dem PC installiert ist.
2. Beenden Sie DIGSI V4.84, bevor Sie das DIGSI V4.84 Hotfix 1 installieren.
3. Kopieren Sie die Datei **lec2Map.dll** in Abhängigkeit Ihrer DIGSI-Installation in das Verzeichnis „...\\DIGSI4“. Üblicherweise ist dies das Verzeichnis C:\\Siemens\\Digs4.
4. Bestätigen Sie die Frage, ob Sie die bestehende Datei überschreiben wollen, mit "Ja".

### Hinweise zur Installation

So erkennen Sie, dass das DIGSI V4.84 Hotfix 1 installiert ist:

Im "Eigenschaften"-Dialog der Datei **lec2Map.dll** (Microsoft Windows-Explorer) ist auf der Karte "Version" die Produktversion „2.12.00“ eingetragen.

### Deinstallation

Es ist weder möglich noch nötig, das DIGSI V4.84 Hotfix 1 zu deinstallieren.

## **Hotline-Kontakt**

Falls Sie Probleme bei der Installation und Benutzung des DIGSI V4.84 Hotfix 1 haben, wenden Sie sich bitte an das Siemens Customer Support Center.

Tel: +49 (180) 524-7000

Fax: +49 (180) 524-2471

E-Mail: [support.energy@siemens.com](mailto:support.energy@siemens.com)

FAQ: <http://www.siemens.com/energy-support>

---

## Readme/Installation Instructions for DIGSI V4.84 Hotfix 1

### New Features and Modifications

The DIGSI V4.84 Hotfix 1 eliminates the following problems:

#### **Unable to update IEC 61850 station**

Problems with updating IEC 61850 stations when DIGSI is set to German have been resolved.

### System Requirements

See DIGSI V4.84.

### Comments to Usage and Restrictions

DIGSI V4.84 must be installed on your PC.

### Compatibility

DIGSI V4.84 Hotfix 1 can only be used to update DIGSI V4.84.

### Contents of the Consignment

DIGSI V4.84 Hotfix 1 contains following files/folders:

- lec2Map.dll
- GNL\_DIGSI-V4.84\_HF1\_Readme.pdf

### Installation

1. Make sure that DIGSI V4.84 is installed on your PC.
2. Please close DIGSI V4.84 before you install the DIGSI V4.84 Hotfix 1.
3. Copy the file **lec2Map.dll** into the folder „...DIGSI4“. This is depending on your DIGSI installation. The usual installation path is C:\Siemens\Digsi4.
4. Confirm the question whether to overwrite the existing file with "Yes".

### Remarks to Installation

How to recognize that DIGSI V4.84 Hotfix 1 has been installed:

In the "Properties" dialog of the file **lec2Map.dll** (Microsoft Windows-Explorer) under the "Version" card, you can identify the file as product version "**2.12.00**".

### Uninstallation

It is neither possible nor necessary to uninstall the DIGSI V4.84 Hotfix 1.

## **Support**

If you have problems with installation and usage of the DIGSI V4.84 Hotfix 1, please contact the Siemens Customer Support Center.

Tel: +49 (180) 524-7000

Fax: +49 (180) 524-2471

E-Mail: [support.energy@siemens.com](mailto:support.energy@siemens.com)

FAQ: <http://www.siemens.com/energy-support>