



# IEC 61850 Certificate Level A<sup>1</sup>

No. 74101108-MOC/INC 11-3051

Issued to:  
Siemens Protection Devices Limited  
North Farm Road, Hebburn,  
Tyne & Wear. NE31 1LX.  
United Kingdom

For the product:  
Reyrolle 7SR210  
Non-Directional Overcurrent Protection  
Firmware Version: 7a  
EN100 V04.08



The product has not shown to be non-conforming to:  
**IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "7SR210 & 7SR220 PICS (R7a-7a)", "7SR210 MICS (R7a-7a)", "7SR210 & 7SR220 TICS (R7a-7a)" and product's extra information for testing: "7SR210 & 7SR220 PIXIT (R7a-7a)".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2b):

1 Basic Exchange (20/24)	9a GOOSE Publish (7/12)
2 Data Sets (3/6)	9b GOOSE Subscribe (10/10)
2+ Data Set Definition (23/23)	12a Direct Control (5/12)
4 Setting Group Selection (2/3)	12c Enhanced Direct Control (5/13)
5 Unbuffered Reporting (15/18)	12d Enhanced SBO Control (10/19)
6 Buffered Reporting (17/20)	13 Time Synchronization (4/5)
6+ Enhanced buffered reporting (10/12)	14 File Transfer (4/7)

This Certificate includes a summary of the test results as carried out at Siemens in United Kingdom with UniCAsim 61850 version 3.23.02 with test suite 3.23.00 and UniCA 61850 analyzer 4.24.02 The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74101108-MOC/INC 11-3050 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by Siemens Protection Devices Limited. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 5 December 2011

M. Adriaansen  
Regional Director Management & Operations Consulting

R.S. Massink  
Test engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2b

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5  Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9  DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10  RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12  BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11
6+: Enhanced buffered reporting	BrE1, BrE2, BrE3, BrE6, BrE7, BrE8, BrE9, BrE10, BrE11	BrE12
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct control	CtlN3, CtlN8  DOns1, DOns3	CtlN11
12c: Enhanced Direct Control	CtlN3, CtlN8  DOes2, DOes5	CtlN11
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9  SBOes1, SBOes2, SBOes3	CtlN11
13: Time sync	Tm1, Tm2, TmN1	Tm3
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	